

# **SAFETY CERTIFICATE**


The Building of Cambridge International School VPO Rajpur Tehsil Palampur Distt Kangra HP was inspected by Junior Engineer of Ghar Section on date 01-07-2024. It has four floors with one building block. It has been observed that no earthquake resistant provisions have been adopted for this building and no structural drawings are approved by any competent Govt. certified Engineer/authority, which have been produced at the time of inspection. More over no assistance was taken from PWD for constructing the building. Hence, the structural safety of this building cannot be ensured. This department will not be responsible for any type of loss of life and property etc., if this structure fail under any circumstances.


However, as per visual inspection the building has been found safe in appearance only. No Officer/Official of this office will attend plea in any Hon'ble court of Law in case of any dispute.

Place: - Palampur

Dated:- 01.07.2024

d/s

  
Executive Engineer  
Palampur Division  
H.P.P.W.D. Palampur

  
Assistant Engineer,  
Palampur Sub-Division,  
H.P.P.W.D. Palampur.